

*Maria Rhinehart
Court Executive Officer /
Jury Commissioner*

*Rodolfo Quintero
Court Finance Officer*



*Superior Court of California,
County of Imperial
939 W. Main Street
El Centro, CA 92243
(760) 336-3522*

R2324-11 Flooring JA & Jury Room#2 RFP

Questions & Answers

issued 05/29/2024

JA DEPARTMENT (2ND FLOOR)

1. Will the items be moved by Court or Contractor?

Court will move copiers to side and items such as trash cans, mats will be lifted/removed from the floor. Contractor will need to lift modular furniture feet to insert carpet. Court will coordinate with contractor at each work phase.

2. What material for the base cove?

Carpet with metal trim.

3. Will there still be an area with vinyl tile?

No, all of the JA department will be carpet tiles.

JURY ROOM #2

4. Will contractor need to do a moisture test?

If required by the manufacturer, yes.

5. What type of cove base?

4 inch Vinyl.

6. What type of transition with hallway?

Vinyl is to toe up with hallway, one continues piece.

OVERALL

7. How many quotes are to be turned in?

Three...

1. JA green area
2. JA red area (all department)
3. Jury room #2